

NOTE: 5'-0" MIN. COVER

## NOTES:

- 1. TOWN OF FRAMINGHAM MAY REQUIRE FLOWABLE FILL AT ITS DISCRETION.
- FOR LOCATIONS WHERE LEDGE IS NOT ENCOUNTERED IN TRENCH, PIPE CAN LAY ON UNDISTURBED EARTH, OR ON SAND BEDDING CONSISTENT WITH AWWA GUIDELINES.
- 3. FOR LOCATIONS WHERE LEDGE IS ENCOUNTERED, SAND BEDDING SHALL BE MINIMUM OF 12" THICK UNDER PIPE.
- 4. FILL MATERIAL SHALL BE COMPACTED TO 95% PROCTOR DENSITY.

NOT TO SCALE



DETAIL NO.